

## Littlemoor House – Fire safety update March 2026

**Responsible person** – First Choice Homes Oldham, 22 Union Street, Oldham, OL1 1BE

**Competent person nominated to implement firefighting measures** – Alex Swift (Fire Safety Manger), Thomas Garrett (Fire Safety Officer), Jack Lent (Property Safety Officer), Clare Oldham (Compliance Contract Officer)

### Fire Risk Assessment – Littlemoor (completed 05/08/2025 by Ethan Davis of Total Fire Group)

To be read in conjunction with the full FRA reports as some actions have been summarised below.

<b>Littlemoor House</b>		
<b>Significant findings</b>	<b>FCHO Update</b>	<b>Estimated completion date</b>
It was observed that the communal door 1084 could not self-close fully and unaided into the doorframe	Works completed 1st September 2025	Complete
It was observed at the time of the fire risk assessment that the wall below the kitchen window sill to flat 31 was damaged, exposing a portion of the frame.	Works completed 29 <sup>th</sup> August 2025	Complete

### Servicing and maintenance – Littlemoor

FCHO has many fire safety measures in place, the below illustrates what’s in place along with its latest maintenance history.

Maintenance activity	Last done	Next due
Full lift service (LOLER)	22/09/2025	22/03/2026
Bin chute service (6 monthly)	01/11/2025	02/05/2026
Dry riser full pressure check (annual)	03/02/2026	03/02/2027
Fire alarm service (annual)	11/03/2026	11/09/2026
Sprinkler service (annual)	05/12/2025	05/12/2026
Evac system service (6 monthly)	24/02/2026	24/08/2026
Lift inspection (monthly)	28/02/2026	31/03/2026
Dry risers (monthly)	28/02/2026	31/03/2026
Sprinklers (monthly)	28/02/2026	31/03/2026
Communal fire doors (3 monthly)	21/01/2026	31/04/2026
Common areas fire safety inspection	21/01/2026	31/04/2026

Flat front entrance doors (annual)	Percentage accessed so far (since 1 <sup>st</sup> April)	100%
------------------------------------	--	------

In addition to the above, weekly fire alarms test are carried out on varying call points.